



State-of-the-Art Reactor Consequence Analyses (SOARCA) Project: Sequoyah Integrated Deterministic and Uncertainty Analyses

2017 International MACCS User's Group Meeting
September 14, 2017


Trey Hathaway
Accident Analysis Branch
Division of Systems Analysis
NRC Office of Regulatory Research

Outline

- Background
- SOARCA Sequoyah Study
- Accident Progression Results
- Sequoyah Site and Region and MACCS Model Development
- MACCS Uncertainty Analysis Results
- Reference and Sensitivity Cases
- Offsite Consequence Analysis Summary
- Sequoyah SOARCA Conclusions

Background

- Relatively low design pressure and smaller volume leads to potential susceptibility to early failure from hydrogen combustion in a station blackout
- Analyzed in Generic Safety Issue program (GSI-189)
- Sequoyah SOARCA analyses supported closure of Fukushima Near Term Task Force (NTTF) activities 5.2 and 6 in SECY-15-0137 and SECY-16-0041





SOARCA Sequoyah Study of Station Blackouts – STSBO MELCOR Uncertain Parameters

Sequence Issues

- Number of cycles to failure-to- close of pressurizer safety valves (SVs) – **pri_SV_cycles**
- Pressurizer SV flow area given failure to close – **pri_SV_frac**
- Number of cycles to failure-to-close of steam generator SVs – **SG_SV_cycles**
- Steam generator SV flow area given failure to close – **SG_SV_frac**
- Time in the burn-up cycle - cycle

In-Vessel Accident Progression

- Melting temperature of the eutectic formed between ZrO_2 and UO_2 – **EU_Melt_T**
- Oxidation kinetics model – **H2_Ox_Corr**

Ex-vessel Accident Progression and Containment Behavior

- Containment failure pressure - **rupture**
- Ice condenser inlet door stuck position following a forceful full opening - **ajar**
- Containment barrier seal failure differential pressure and area – **Seal_Fail_Dp/Seal_Open_A**

Hydrogen Combustion


- Flammability (direction of flame propagation from an ignition source) – **burn_dir**

Aerosol Transport and Deposition

- Dynamic shape factor – **shape_factor**

Accident Progression Results

Long-term containment over-pressurization failure due to prolonged steam production and non-condensable gas generation




Early containment overpressure failures due to sufficiently large burns in containment



No BOC cases exhibit long-term overpressure failure before 72 hours

Accident Progression Results

All realizations - Iodine



All realizations - Cesium





Sequoyah Site and Region

- Two-unit nuclear power plant site in Hamilton County, TN
 - Analysis assumes Short-term Station Blackout (STSBO) occurring at Unit 1
 - 18 miles NE of Chattanooga, TN
 - Approximately 98,000 people in 10-mile radius EPZ
 - Approximately 1,100,000 people in 50-mile radius EPZ
 - Population scaled from 2010 Census data to 2015



<https://www.flickr.com/photos/nrcgov/6517605543/>


Sequoyah Site and Region




MACCS Model Development



10 mile EPZ



- Nine evacuation cohorts defined
 - Includes schools, special facilities, transit-dependent, general public, shadow, non-evacuees
- Initiating event is a beyond-design-basis earthquake
- Analysis assumes bridges in 10-mile EPZ unusable ()
- Calculate average evacuation time of ~ 9 hrs for base case
- Considering different characteristics of the 9 cohorts, EPZ evacuation completed about 17 hrs after accident initiation for base case (~14 hours after GE siren or emergency alerting)

RtePM screenshot
showing road network

MACCS Uncertain Parameter Groups

Deposition

- Wet Deposition
- Dry Deposition Velocities

Dispersion

- Crosswind Dispersion Linear Coefficient
- Vertical Dispersion Linear Coefficient
- Time-Based Crosswind Dispersion Coefficient

Latent Health Effects

- Dose and Dose Rate Effectiveness Factor
- Lifetime Cancer Fatality Risk Factors
- Long Term Inhalation Dose Coefficients

Early Health Effects

- Threshold Dose
- Lethal Dose to 50% of population
- Hazard Function Shape Factor

Shielding Factors

- Groundshine Shielding Factors
- Inhalation Protection Factors

Emergency Response

- Evacuation Delay
- Evacuation Speed
- Hotspot Relocation Time and Dose Criteria
- Normal Relocation Time and Dose Criteria
- Keyhole Forecast Time

Aleatory Uncertainty

- Weather Trials

MACCS Uncertainty Analysis Results – Distribution of Mean (over weather variation) Individual Latent Cancer Fatality Risk

	0-10 Miles	10-20 Miles	20-30 Miles	30-40 Miles	40-50 Miles	0-50 Miles
Mean	8.0E-05	9.7E-05	1.0E-04	8.2E-05	6.6E-05	8.8E-05
Median	6.7E-05	7.5E-05	9.1E-05	7.8E-05	6.2E-05	8.1E-05
5th Percentile	1.2E-08	2.7E-09	1.1E-09	4.2E-10	2.6E-10	2.3E-09
95th Percentile	2.0E-04	2.5E-04	2.4E-04	1.8E-04	1.4E-04	2.1E-04

MACCS Uncertainty Analysis – Regression Results

0 – 10 Mile										Main Contribution	Conjoint Contribution
	Rank Regression		Quadratic		Recursive Partitioning		MARS				
Final R ²	0.67		0.86		0.58		0.78				
Input	R ² contr.	SRRC	S _i	T _i	S _i	T _i	S _i	T _i			
Cycle	0.36	0.58	0.23	0.29	0.40	0.60	0.20	0.20	0.237	0.056	
priSVcyc	---	---	0.04	0.15	0.12	0.15	0.14	0.31	0.070	0.083	
CFRISK(8)	0.09	0.29	0.07	0.12	0.08	0.23	0.10	0.09	0.068	0.042	
Rupture	0.06	-0.24	0.06	0.08	0.07	0.18	0.09	0.15	0.054	0.046	
CFRISK(7)	0.03	0.19	0.06	0.10	0.05	0.11	0.08	0.10	0.040	0.031	
GSHFAC_6(2)	0.05	0.22	0.02	0.06	0.01	0.05	0.04	0.03	0.026	0.021	
CFRISK(6)	0.01	0.09	0.04	0.11	---	---	0.04	0.07	0.018	0.029	
CFRISK(3)	0.02	0.11	---	---	0.00	0.01	0.03	0.10	0.011	0.018	
DDREFA(8)	0.01	-0.11	0.03	0.04	---	---	---	---	0.010	0.002	

* highlighted if main contribution larger than 0.02 or conjoint contribution larger than 0.1

0 – 50 Mile										Main Contribution	Conjoint Contribution
	Rank Regression		Quadratic		Recursive Partitioning		MARS				
Final R ²	0.59		0.86		0.65		0.75				
Input	R ² contr.	SRRC	S _i	T _i	S _i	T _i	S _i	T _i			
Cycle	0.23	0.52	0.24	0.31	0.36	0.44	0.21	0.21	0.208	0.038	
CFRISK(8)	0.06	0.24	0.09	0.13	0.05	0.14	0.09	0.08	0.059	0.029	
Rupture	0.05	-0.21	0.06	0.10	0.05	0.22	0.10	0.25	0.052	0.086	
CFRISK(4)	0.05	0.23	0.07	0.10	0.04	0.15	0.08	0.09	0.048	0.037	
CFRISK(7)	0.04	0.22	0.05	0.07	0.02	0.10	0.08	0.11	0.040	0.028	
TIMNRM	0.04	0.22	0.04	0.07	0.06	0.30	0.05	0.06	0.038	0.061	
CYSIGA(1)	0.03	0.19	0.03	0.04	0.01	0.05	---	---	0.015	0.013	
DDREFA(4)	0.02	-0.13	0.02	0.02	0.00	0.04	0.02	0.02	0.013	0.011	
CFRISK(6)	0.01	0.08	0.03	0.12	---	---	0.02	0.08	0.012	0.042	

* highlighted if main contribution larger than 0.02 or conjoint contribution larger than 0.1

Reference and Sensitivity Cases

- All cases assume seismic impact on evacuation network
- Reference case
 - Nominal shielding parameters
 - Evacuation order
 - Basis for uncertainty analysis
- Sensitivity cases
 - Shelter-in-place (SIP) while offsite response organization evaluates infrastructure
 - Shielding changes due to seismically degraded buildings
 - Weather year
 - Non-LNT dose response


Reference and Sensitivity Cases

MELCOR Realization	Scenario	Time in Cycle	Release Fraction		Released Activity (Bq)		Time (hr)	
			Cs	I	Cs-137	I-131	Start *	Increase **
266	STSBO Reference	MOC	0.001	0.004	1.4E+14	1.1E+16	3.4	57.6
554	STSBO Earliest Release	EOC	0.018	0.051	7.3E+15	1.6E+17	2.7	3.6
395	STSBO Highest Cs Release Mass	EOC	0.027	0.079	1.1E+16	2.6E+17	2.9	6.9
36	STSBO Highest Cs Release Fraction	MOC	0.036	0.107	9.7E+15	3.4E+17	3	7
146	Large Release at 56 hours	MOC	0.029	0.089	7.9E+15	2.4E+17	2.6	55.6
382	Release at 40 hours	EOC	0.001	0.008	4.0E+14	2.3E+16	3.3	40.3

*The “start” time indicates the timing of the first environmental release, no matter how small.


**The “increase” time indicates the timing of the first significant increase in the rate of release.

Reference and Sensitivity Cases: Results




- Conditional individual LCF risks generally decrease at longer distances

Reference and Sensitivity Cases: Population Movement Compared to Early Releases




Reference and Sensitivity Cases: Sensitivity 1 and 2: SIP and shielding factor due to seismically degraded buildings (0-10 miles)



- Conditional individual LCF risks
 - Are roughly 1E-04 in 0- to 10-mile region for late releases
 - Are roughly 1E-03 in 0- to 10-mile region for early releases


Reference and Sensitivity Cases: Sensitivities 1 and 2: Mean Conditional Individual LNT LCF Risks for SIP and Shielding Factor Variations



- 48-hour shelter-in-place increases 10-mile EPZ risks
 - By factor-of-2+ with nominal shielding factors
 - By factor-of-7+ with fully degraded shielding factors

Reference and Sensitivity Cases

Sensitivity 3: Impact of Weather Year Risk



Conditional individual LCF risks are nearly independent of weather

Offsite Consequence Analysis Summary

- Individual, conditional LCF risks:
 - Range from about 1E-09 to 1E-03
 - Generally decrease at longer distances
 - Generally dominated by intermediate and long-term phase exposures compared to emergency phase exposures
 - Increase but by less than an order of magnitude for 48-hour shelter-in-place and degraded shielding factors
 - Nearly independent of weather year
 - Decrease with increasing dose-truncation level
- Parameters most important to uncertainty in individual LCF risk:
 - Time of accident during fuel cycle (most important at all distances)
 - Cancer fatality risk factors for “residual” organ, lungs, and colon
 - Containment rupture pressure
 - Number of safety valve cycles prior to failing open (more important at shorter distances)
 - Normal relocation time (more important beyond 10-mile EPZ)
 - Groundshine shielding factors (more important within 10-mile EPZ)

Sequoyah SOARCA Conclusions

- For unmitigated STSBO (without igniters), the two potential containment outcomes are either early or late failure
- Successful use of igniters averts early containment failure
- Essentially zero individual early fatality risk was calculated for Sequoyah STSBO
- Even for cases resulting in early release to environment, the conditional individual LCF risk is small
- Conditional individual latent cancer fatality risk results for Sequoyah are similar in magnitude to those from other SOARCA analyses

Acronyms & Abbreviations

AC	Alternating Current	MSIV	Main Steam Isolation Valve
BOC	Beginning of Cycle	NTTF	Fukushima Near-Term Task Force
CCDF	Complementary Cumulative Distribution Function	PDF	Probability Density Function
CCI	Core Concrete Interactions	PGA	Peak Ground Acceleration
CDF	Core Damage Frequency	PRA	Probabilistic Risk Assessment
CST	Condensate Storage Tank	PRT	Pressurizer Relief Tank
DC	Direct Current	PZR	Pressurizer
EOC	End of Cycle	RCP	Reactor Coolant Pump
EPZ	Emergency Planning Zone	RCS	Reactor Coolant System
EF	Early Fatality	RLZ	Realization
HL	Hot Leg	RPV	Reactor Pressure Vessel
FLEX	Diverse and Flexible Coping Strategies	RtePM	Real Time Evacuation Planning Model
FTC	Failure to Close	SBO	Station Blackout
FTO	Failure to Open	SG	Steam Generator
LCF	Latent Cancer Fatality	SIP	Shelter in Place
LNT	Linear No Threshold	SNL	Sandia National Laboratories
LTSBO	Long-Term Station Blackout	SOARCA	State-of-the-Art Reactor Consequence Analysis
MACCS	MELCOR Accident Consequence System	Code	Short-Term Station Blackout
MCR	Main Control Room	STSBO	Safety Valve
MELCOR	Not an acronym - accident progression code	SV	Turbine Driven Auxiliary Feedwater System
MeIMACCS	MELCOR to MACCS Source Term Converter	TDAFW	Tennessee Valley Authority
MOC	Middle of Cycle	TVA	Uncertainty Analysis
		UA	