

THE IMPACT OF WEATHER ON RADIOLOGICAL DOSE PROJECTIONS

IMUG MEETING
JUNE 10, 2019

TODD SMITH, PhD

EMERGENCY PREPAREDNESS SPECIALIST
OFFICE OF NUCLEAR SECURITY AND INCIDENT RESPONSE

USNRC

EMERGENCY PREPAREDNESS

a state of readiness to respond to a hazard to protect the health and safety of the public.


INCIDENT RESPONSE

integrates NRC capabilities for the response and recovery of radiological incidents.

EMERGENCY PREPAREDNESS

INCIDENT RESPONSE



Emergency Planning Zones



EMERGENCY PREPAREDNESS

INCIDENT RESPONSE

Basis for EPZs NUREG-0396 Methodology



EMERGENCY PREPAREDNESS

INCIDENT RESPONSE



- Ensure utility actions protect public health and safety
- Support State/Local response efforts
- Support larger Federal response

Independent reactor and offsite dose assessment

EMERGENCY PREPAREDNESS

INCIDENT RESPONSE



EMERGENCY PREPAREDNESS

INCIDENT RESPONSE

Source Term to Dose - [test 2018-05-11 1025.std]

File Settings Nuclide Data Viewer Help

☒ **Event Type**
NPP Reactor

☒ **Event Location**
Wolf Creek - Unit 1

☒ **Source Term**
☐ Import
Effluent Releases - by Mixtures

☒ **Release Path**
Direct to atmosphere

☒ **Meteorology**
Predefined Conditions

☒ **Calculate Doses**

☒ **Detailed Results**

☒ **Save Case**

Case Summary

Event Type

Case description
None

Location
Name:
City, county, state:
Lat / Long / Elev:
Time zone:
Population (2010):

Reactor Parameters
Reactor power:
Average burnup:
Containment type:
Containment volume:
Design pressure:
Design leak rate:

Case Summary

RASCAL

- Source Term
 - Determines time-dependent isotopes and activities
- Atmospheric Transport and Dispersion
 - Transports material downwind


$$C(x, y, z) = \frac{Q}{2\pi u \sigma_y \sigma_z} e^{-\frac{y^2}{2\sigma_y^2}} \left(e^{-\frac{(z+H)^2}{2\sigma_z^2}} + e^{-\frac{(z-H)^2}{2\sigma_z^2}} \right)$$

- Dose Calculations
 - Determines dose based on deposited material
 - Comparable to PAGs; helps inform protective actions

UPCOMING CHALLENGES FOR BOTH PROGRAMS

Small modular and advanced reactor designs will significantly reduce the risk of an offsite radiological release. These design enhancements have implications for:

- EPZ size determination
- Dose Assessment Capabilities
- Protective Action Strategies
- Physical and Cyber Security



Design Project Statement

How will new reactor technologies affect current assumptions and methodologies for radiological dose projections?


Enhance Preparedness - Understand the sensitivity of weather related factors to inform emergency planning and EPZ size

Improve Response - Assess the adequacy of RASCAL modeling using SMR source terms and close-in projections



Sensitivity of Dose Projections

Constraints



Source Term

Representative SMR

RASCAL Field Entry to Produce Source Term	User Defined Parameter
Reactor Type	Generic PWR with Large, Dry Containment
Name	TVA-1
Location	Clinch River, Chattanooga, TN (Location of first NuScale plant)
Assemblies [#]	37
Containment Volume [ft ³]	6,978.43
Coolant Mass [kg]	2,520.28
Steam Generator Water Mass [kg]	17,584.76
Steaming Rate [kg/hr]	201,960
Reactor Power [MWt]	160
Average Burnup (in reactor) [MWd/MTU]	45,556
Discharge Burnup (spent storage) [MWd/MTU]	35,206
Release Height [m]	10

Location and Plant Parameters of Nuclear Power Plant

☐ Load Existing Nuclear Power Plant Site from Database
☒ Define a "Generic" Nuclear Power Plant Site

Type: Time Zone:

Name: (required) ☒ United States

City:

Country:

State:

Country:

Latitude: degrees (required)

Longitude: degrees (required)

Elevation: meters

Number of assemblies in core:

Containment volume: ft³

Coolant mass: kg

SG water mass: kg

Default SG steaming rate: kg/h

Reactor power: MWt

Average burnup - in reactor: MWd/MTU

Discharge burnup - in spent fuel storage: MWd/MTU

OK Cancel Help


LOCA

LTSBO

36% cladding damage

100% per hour containment leakage (no containment)

Core uncovers and release begins in 1 hour



LOCA

LTSBO

1% core melt

8% per hour containment leakage


Core uncovers and release begins in 8 hours

Maximum Dose Values (rem) - Close-In

Dist from release

miles	0.1	0.2	0.3	0.5	0.7	1.	1.5	2.
(kilometers)	(0.16)	(0.32)	(0.48)	(0.8)	(1.13)	(1.61)	(2.41)	(3.22)
Total EDE	<u>8.7E+01</u>	<u>2.8E+01</u>	<u>1.5E+01</u>	<u>6.7E+00</u>	<u>4.0E+00</u>	<u>2.3E+00</u>	<u>1.3E+00</u>	<u>1.0E+00</u>
Thyroid CDE	<u>1.1E+03</u>	<u>3.4E+02</u>	<u>1.8E+02</u>	<u>8.3E+01</u>	<u>4.9E+01</u>	<u>2.8E+01</u>	<u>1.6E+01</u>	<u>1.2E+01</u>
Inhalation CEDE	<u>5.1E+01</u>	<u>1.6E+01</u>	<u>8.6E+00</u>	<u>3.9E+00</u>	<u>2.3E+00</u>	<u>1.3E+00</u>	<u>7.6E-01</u>	<u>5.9E-01</u>
Cloudshine	<u>8.6E-01</u>	<u>4.2E-01</u>	<u>2.8E-01</u>	<u>1.5E-01</u>	<u>1.0E-01</u>	<u>6.0E-02</u>	<u>4.1E-02</u>	<u>3.5E-02</u>
4-day Groundshine	<u>3.5E+01</u>	<u>1.1E+01</u>	<u>5.9E+00</u>	<u>2.7E+00</u>	<u>1.6E+00</u>	<u>8.9E-01</u>	<u>5.2E-01</u>	<u>4.0E-01</u>
Inter Phase 1st Yr	<u>4.2E+02</u>	<u>1.3E+02</u>	<u>7.1E+01</u>	<u>3.2E+01</u>	<u>1.9E+01</u>	<u>1.1E+01</u>	<u>6.3E+00</u>	<u>4.9E+00</u>
Inter Phase 2nd Yr	<u>2.6E+02</u>	<u>8.2E+01</u>	<u>4.4E+01</u>	<u>2.0E+01</u>	<u>1.2E+01</u>	<u>6.6E+00</u>	<u>3.9E+00</u>	<u>3.0E+00</u>


RASCAL MODEL FOR DOSE PROJECTION




Stability Class

Sensitivity Analysis


STABILITY CLASS F (STABLE)



STABILITY CLASS B (UNSTABLE)



Wind Speed Sensitivity Analysis




VARIABLE WIND SPEED

STABILITY CLASS D

NO RAIN

Stability Class

Sensitivity Analysis




4 MPH WIND

VARIABLE STABILITY CLASS

NO RAIN

Precipitation Sensitivity Analysis



4 MPH WIND

STABILITY CLASS D

VARIABLE RAIN


Realistic Weather Scenario Development

- Real 2 day, hourly weather data from site compared to historical daily average
- Stability class for each one was estimated based on Stability Class Chart and compared to historical daily average
- Four weather cases tested:
 - Daytime Release (8 am) without Rain
 - Nighttime Release (7 pm) without Rain
 - Daytime Release with Rain (13 hours)
 - Nighttime Release with Rain




Realistic Weather LOCA


DAYTIME NO RAIN




NIGHTTIME NO RAIN



DAYTIME RAIN




NIGHTTIME RAIN




Realistic Weather

LTSBO


DAYTIME NO RAIN




NIGHTTIME NO RAIN



DAYTIME RAIN



NIGHTTIME RAIN




Delayed Release Scenario Development

- SMRs and advanced reactors designed to delay or prevent release
- RASCAL model adjustments
 - LOCA - Set delay from time of reactor shutdown and when core uncovered
 - LTSBO - Set delay by increasing ECCS operation time (limit 48 hours)
- Base Case: Using standard meteorology for 96 hours after release
 - 4 mph wind speed, winds to East
 - Stability Class D




Delayed Release LOCA


No DELAY



48 HOUR DELAY



96 HOUR DELAY



CONCLUSIONS

- EPZ size is sensitive to weather related phenomena. Wind speed and persistence, stability class, and precipitation are all important to some degree.
- Dispersion modeling is important: many factors vary significantly within a short distance, creating large variation in dose-at-distance.
- Release timing and release rate are important to the sensitivity analysis.

INSIGHTS AND RECOMMENDATIONS

- Realistic, site-specific weather patterns should be used for EPZ size determination analyses as opposed to simple, conservative assumptions.
- Advanced reactors that minimize source term or delay potential releases can reduce emergency planning needs (commensurate to risk).
- The NRC may want to consider technology-neutral source term models for RASCAL to enhance emergency response capabilities.



Questions?

Todd Smith, PhD

Emergency Preparedness Specialist
U.S. Nuclear Regulatory Commission
(301)-287-3744

Todd.Smith@nrc.gov

Jeff Kowalczyk, CHP

Emergency Response Coordinator
U.S. Nuclear Regulatory Commission
(301)-287-3755

Jeff.Kowalczyk@nrc.gov