



# MACCS Code Applicability for Nearfield Consequence Analysis



PRESENTED BY

**Dan Clayton**

**Sandia National Laboratories**

**International MACCS User's Group (IMUG)  
meeting, September 20, 2021**



Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology & Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.  
**SAND2021-7608 PE**

# Outline

Introduction/Setup

Code Trends

Code Comparisons

MACCS Updates

Wrap up

## Introduction (1/2)

1. The **adequacy** of the MELCOR Accident Consequence Code System (**MACCS**) in the **nearfield** is discussed in a **non-Light Water Reactor (LWR) vision and strategy report** that discusses computer code readiness for non-LWR applications developed by the Nuclear Regulatory Commission (NRC)
2. MACCS currently includes a **simple model** for building wake effects. The MACCS2 User's Guide suggests that this simple building wake model **should not be used at distances closer than 500 m**. This statement raises the first question of **whether MACCS can reliably be used to assess nearfield doses**, i.e., at distances less than 500 m

## Introduction (2/2)

3. MACCS is a **highly flexible** Gaussian model and the **user can choose whether to model a variety of physical phenomena**, including:


- Building wake effects
- Plume buoyancy
- Plume meander

Furthermore, the user has flexibility in choosing how to model the Gaussian dispersion parameters

4. Second question, can MACCS be used in the nearfield? If so, **how can MACCS be used to generate results that are bounding** of other codes intended for nearfield analysis

5

# General Arrangement of Flow Zones Near a Sharp-edged Building



Meteorology and Atomic Energy, 1968

## Objective

An **evaluation of modeling approaches (methods)** to estimate nearfield air concentrations and depositions **was performed** where several **candidate codes** were **ranked for comparison** and potential incorporation into the MACCS code

In this assessment, it is **assumed** that the **results from the selected codes** are all **adequate in the nearfield**, which is reasonable because these codes are specifically intended to be used in the nearfield

Hence, by **comparing the results** of these codes to the results from MACCS, the **adequacy of MACCS for assessing exposures in the nearfield** can be evaluated, along with determining how **MACCS** can be used to generate **bounding results**

## 7 Nearfield Code List

Four **candidate codes** were selected from the three **main methods** of atmospheric transport and dispersion (ATD) in the nearfield and evaluated

- CFD models – OpenFOAM
- Simplified wind-field models – QUIC
- Modified Gaussian models – AERMOD and ARCON96

| Model    | Model Characteristics |            |            |                   |                      |                        |
|----------|-----------------------|------------|------------|-------------------|----------------------|------------------------|
|          | Simplicity            | Efficiency | Validation | Conservative Bias | Community Acceptance | Ease of Implementation |
| OpenFOAM | 3                     | 3          | 1          | 2                 | 1                    | 3                      |
| QUIC     | 3                     | 2          | 1          | 2                 | 2                    | 3                      |
| ARCON96  | 1                     | 1          | 2          | 2                 | 1                    | 1                      |
| AERMOD   | 1                     | 1          | 1          | 2                 | 1                    | 2                      |

Based on these rankings, QUIC, AERMOD, and ARCON96 were selected for comparison with MACCS

# Test Cases

## Two weather conditions

- 4 m/s, neutrally-stable (D stability class) – typical condition
- 2 m/s, stable (F stability class) – reduced dispersion condition

## Three building configurations (HxWxL)

- 20m x 100m x 20m (5:1 W:H) – extreme width to height ratio
- 20m x 40m x 20m (2:1 W:H) – typical building size
- No building (point source) – evaluate differences for elevated releases with no building

## Two power levels (heat content)

- 0 MW – without buoyancy
- 5 MW – with buoyancy

| Weather/Energy Content   | Building HxWxL (m) |          |        |
|--------------------------|--------------------|----------|--------|
|                          | 20x100x20          | 20x40x20 | None   |
| 4 m/s, D stability, 0 MW | Case01             | Case05   | Case09 |
| 2 m/s, F stability, 0 MW | Case02             | Case06   | Case10 |
| 4 m/s, D stability, 5 MW | Case03             | Case07   | Case11 |
| 2 m/s, F stability, 5 MW | Case04             | Case08   | Case12 |





# Code Trends





# MACCS Results

**Building** and **elevation** effects greatly **diminished** at 800 m downwind

**Building** significantly **increases dispersion** at short distances

Dilution for **stable** conditions generally **higher** than the corresponding dilution for **neutrally-stable** conditions

**Buoyant plumes** that escape building wake produce significantly **lower dilution values** due to fast plume rise compared with dispersion





# ARCON96 Results

Minimal change due to inclusion of **building** or **elevated** release within 1 km

Dilution for **stable** conditions generally **higher** than the corresponding dilution for **neutrally-stable** conditions

No plume rise model implemented; buoyant cases were not modeled





# AERMOD Results

**Building** and **elevation** effects greatly **diminished** at 500 m downwind

**Building** significantly **increases dispersion** at short distances

Dilution for **stable** conditions generally **higher** than the corresponding dilution for **neutrally-stable** conditions

**Minor differences** due to buoyancy





# QUIC Results (1/2)

**Building** and **elevation** effects greatly **diminished** at 1 km downwind

**Building** significantly **increases dispersion** at short distances

Dilution for **stable** conditions generally **higher** than the corresponding dilution for **neutrally-stable** conditions


No straightforward way to implement buoyancy; buoyant cases were not modeled





# QUIC Results (2/2)

Horizontal and vertical slices for a 4 m/s, neutrally-stable weather condition with a non-buoyant, elevated release from a 20 m x 100 m x 20 m building (Case 01)





# Code Comparisons




# Comparison Results

At 50 m, order from  
**highest to lowest  
dilution** is ARCON96,  
AERMOD, QUIC,  
MACCS

**Order changes with  
distance**

- ARCON96 shifts from highest to lowest
- AERMOD shifts from 2<sup>nd</sup> highest to 2<sup>nd</sup> lowest
- Relative order between QUIC and MACCS is consistent






## 17 Potential Modifications to MACCS Input

1. Specify a **ground-level release**, instead of a release at the height of the building
  - **ARCON96** model showed **little dependence on elevation** of release
  - **Wake-induced building downwash** observed in QUIC output
  - **Regulatory Guide 1.145** discusses releases less than 2.5 times building height should be modeled as **ground-level releases**
2. Specify **no buoyancy** (plume trapped in building wake)
  - **AERMOD** model showed **little dependence on buoyancy**
3. If **additional conservatism** needed or desired, model as a **point source**
  - **ARCON96** model showed **little dependence on building size**
  - **DOE** approach used for **collocated workers**
  - If point source **too bounding**, use an **intermediate building wake size**

# Updated Comparison Results

**MACCS** input **modified**  
to reflect a ground-level  
(1), non-buoyant (2)  
release (grey) **bounds**  
**AERMOD** and **QUIC**  
up to 1 km and  
**ARCON96** from 200 m  
up to 1 km

**MACCS** input **modified**  
to reflect a ground-level  
(1), non-buoyant (2),  
point-source (3) release  
(light blue) **bounds all**  
**three** up to 1 km





# MACCS Updates



# MACCS Update Plan



Provide **additional capabilities** in **MACCS** to facilitate **simulating** or **bounding** nearfield calculations performed with **other codes**

- Ramsdell and Fosmire meander model used in ARCON96
- US NRC Regulatory Guide 1.145 meander model as implemented in PAVAN
- Maintain existing MACCS capabilities


## Plume Meander

- ☒ US NRC Regulatory Guide 1.145 (MNDMOD=NEW)
- ☐ Ramsdell and Fosmire (MNDMOD=PAF)
- ☐ Original MACCS (MNDMOD=OLD)
- ☐ None (MNDMOD = OFF)

## 21 Verification Results (1/2)





20 m x 40 m x 20 m building,  
2 m/s, F stability







# Verification Results (2/2)




20 m x 100 m x 20 m building,  
4 m/s, D stability




# Model Comparisons (1/2)




20 m x 40 m x 20 m building,  
4 m/s, D stability



# Model Comparisons (2/2)



20 m x 100 m x 20 m building,  
2 m/s, F stability







Wrap up



## Summary (1/4)

**ARCON96, AERMOD, and QUIC** selected for **comparison** with **MACCS** based on initial evaluation

**Test cases** developed to give a **broad range** of conditions, **not** to be **exhaustive**

- Two weather conditions
- Three building configurations
- Two buoyancy variations

## Summary (2/4)



**MACCS** calculations configured with **point-source, ground-level, nonbuoyant plumes** provide conservative nearfield results that **bound** the centerline, ground-level air concentrations from **ARCON96, AERMOD, and QUIC**

**MACCS** calculations with **ground-level, nonbuoyant plumes** that include the effects of the building wake (area source) provide nearfield results that **bound** the results from **AERMOD and QUIC** and the results from **ARCON96** at distances **>200 m**

If using a **point-source** is **too conservative** and it is desired to bound the results from all three codes, another **alternative** is to use area source parameters in **MACCS** that are less than the standard values, i.e., an area source **intermediate** between the standard recommendation and a point source

## Summary (3/4)



**MACCS can be used** at distances significantly shorter than 500 m downwind (50 – 200 m) from a containment or reactor building

However, the MACCS user needs to **select** the MACCS input **parameters appropriately** to generate results that are adequately conservative for a specific application

**A conservative nearfield result** may be obtained using the **following MACCS parameter choices:**

- The parameterization of Eimutis and Konicek for the dispersion model
- The plume meander model based on Regulatory Guide 1.145. This model is selected by setting the value of the MACCS parameter MNDMOD to NEW
- The release modeled as a point-source, ground-level, nonbuoyant plume

## Summary (4/4)



### Additional **nearfield meander models** are **included** with **MACCS 4.1**

- Simulate results from ARCON96 with MACCS when using the Ramsdell and Fosmire meander model
- Simulate results from PAVAN with MACCS when using the full US NRC Regulatory Guide 1.145 meander model
- Maintain capability to bound AERMOD and QUIC results using recommended MACCS parameter choices

### **Comparing** the plume meander model **results** shows

- When using the full **US NRC Regulatory Guide 1.145 meander model**, the X/Q values for the test cases are **higher** than for the other two models
- The X/Q values for the test cases with **MACCS Ramsdell and Fosmire plume meander model** are lower than the other two models except at distances of less than 200-300 m
- Beyond 1 km, **the three models converge** with differences on the order of 5-10% at a distance of 35 km.